
NI's Comments on IEEE 1451.2

David Potter
National Instruments



Integrated Measurement and Automation Systems



NI and Smart Sensors: The Big Picture...

- Smart sensors will be increasingly important in Measurement and Automation
 - Main driver: easier connectivity and use of sensors
- 'Smart' sensors, smart modules, smart systems,...
 - "What is smart" is less important than building integrated systems that deliver the end user benefits
- NI as both software and hardware supplier
 - As software supplier: support many networks, devices, instruments, as requested and required by customers
 - As hardware supplier: highly selective of technology for interfaces



As hardware supplier... Possible Implementations?

Plug-In DAQ







PXI DAQ





Networked I/O (DAQ)




1451.2 TTI?

ni.com




Smart Sensor System Model





Traditional Partitions



1451.2

Analog (0-5V, 0-10V, mV, 4-20 mA)

Network




NI's Thoughts/Reactions on dot2

- Partition Location
 - 1451.4 partition at analog is good fit
- Seemed more appropriate as OEM (chip-level, module) level interface, rather than an end user interface
- Standardized TEDS can ease setup, configuration
 - Particularly useful: calibration information
 - Very useful if can somehow used across multiple electrical/physical implementations




"Generalized" TEDS?





"Generalized" TEDS?



Generalized TEDS should be able to describe characteristics of these elements



Software

Other LabVIEWTM **Software Measurement and Control Services Device/Network Configuratino Device and Protocol Drivers Mixed Mode** Neworked (1451.4)Sensor (1451.3, 1451.2?)

TEDS Database



NI's Thoughts/Reactions on dot2

- Partition Location
 - 1451.4 partition at analog is good fit
- Seemed more appropriate as OEM (chip-level, module) level interface, rather than an end user interface
- Standardized TEDS can ease setup, configuration
 - Particularly useful: calibration information
 - Very useful if can somehow used across multiple electrical/physical implementations



